



Both Contactors have 120 volt coils which will be transformer 220-120volt isolated. The Start Stop has DPDT with the Start switch held for motor startup then latched Stop open the latch releasing Contactor 1. Since the transformer is on both legs of 220v either open stops.

Jim Mora
9/25/2006